

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF _____ FILE _____

DATE _____ September 7, 1984 _____

DEPARTMENT _____

On Thursday, August 30, 1984, Chuck Griffin learned that a pressure line on the lift station at Valley View and Shady Glenn was cracked and reported it to this office. Sewage was flowing from the lift station into the Horseshoe sink hole. Gene Pabst and I applied chlorine to the raw sewage and reported the spill to DNR. Sewer maintenance crews had the cracked pipe repaired by midnight on Thursday. An estimated 30,000 gallons of sewage was spilled.

cc: Ed Sears, MDNR

32005 Valley View

Karen Chandler
Karen Chandler
WPCI II
SIGNED S & E